



Candidate: _____

Successful

Evaluator: _____

Unsuccessful

Date: _____

1002-PROCESS 14

| | |
|-----------------------------|--|
| Standard: | NFPA 1002 – 2017 edition – 5.1.2 |
| Task: | Perform the visual and operational checks on the systems and components specified in the following list: (1) water tank and other extinguishing agent levels (if applicable) (2) pumping systems (3) foam systems |
| Performance Outcome: | The operational status of the pumper is verified. |
| Conditions: | Given a fire department pumper, its manufacturer’s specifications, and policies and procedures of the jurisdiction. |
| Candidate Directive: | “Perform the visual and operational checks on the systems and components specified in the list provided.” |

| NO. | TASK STEPS | TEST | |
|-----|---|------------|--------------|
| | | Successful | Unsuccessful |
| | Performed visual and operational checks on the water tank and other extinguishing agent levels (if applicable). | | |
| | Performed visual and operational checks on the pumping systems. | | |
| | Performed visual and operational checks on the foam systems. | | |

Evaluator/Candidate Comments:



Candidate: _____

Successful

Evaluator: _____

Unsuccessful

Date: _____

1002-SKILL-15

| | |
|-----------------------------|---|
| Standard: | NFPA 1002 – 2017 edition – 5.2.1 |
| Task: | Respond on apparatus to an emergency scene. |
| Performance Outcome: | The apparatus is correctly mounted and dismantled and seat belts are used while the vehicle is in motion. |
| Conditions: | Given safety equipment as provided by the AHJ. |
| Candidate Directive: | “Respond on apparatus to an emergency scene.” |

| NO. | TASK STEPS | TEST | |
|-----|---|------------|--------------|
| | | Successful | Unsuccessful |
| 1 | The apparatus was correctly mounted. | | |
| 2 | Seat belts were used while the vehicle was in motion. | | |
| 3 | The apparatus was correctly dismantled. | | |

Evaluator/Candidate Comments:



Candidate: _____

Successful

Evaluator: _____

Unsuccessful

Date: _____

1002-PROCESS 16

| | |
|-----------------------------|---|
| Standard: | NFPA 1002 – 2017 edition – 5.2.2 |
| Task: | Establish and operate in work areas at emergency and nonemergency scenes. |
| Performance Outcome: | Procedures are followed, safety equipment is utilized, protected work areas are established as directed using traffic and scene control devices, and the driver/operator performs assigned tasks only in established, protected work areas. |
| Conditions: | Given safety equipment, traffic and scene control devices, emergency and nonemergency scenes, traffic and other hazards, an assignment, and SOPs. |
| Candidate Directive: | “Establish and operate in work areas at emergency and nonemergency scenes.” |

| NO. | TASK STEPS | TEST | |
|-----|---|------------|--------------|
| | | Successful | Unsuccessful |
| 1 | Followed procedures. | | |
| 2 | Utilized safety equipment. | | |
| 3 | Established protected work areas using traffic and scene control devices. | | |
| 4 | Performed tasks in established, protected work areas. | | |

Evaluator/Candidate Comments:



Candidate: _____

Successful

Evaluator: _____

Unsuccessful

Date: _____

1002-SKILL-17

| | |
|-----------------------------|---|
| Standard: | NFPA 1002 – 2017 edition – 5.2.3 |
| Task: | Connect a fire department pumper to a water supply as a member of a team. |
| Performance Outcome: | Connections are tight and water flow is unobstructed. |
| Conditions: | Given supply or intake hose, hose tools, and a fire hydrant or static water source. |
| Candidate Directive: | “Connect a fire department pumper to a water supply as a member of a team.” |

| NO. | TASK STEPS | TEST | |
|-----|------------------------------|------------|--------------|
| | | Successful | Unsuccessful |
| 1 | Connections were tight. | | |
| 2 | Water flow was unobstructed. | | |

Evaluator/Candidate Comments:



Candidate: _____

Successful

Evaluator: _____

Unsuccessful

Date: _____

1002-PROCESS 18

| | |
|-----------------------------|---|
| Standard: | NFPA 1002 – 2017 edition – 5.2.4 |
| Task: | Produce effective hand or master streams. |
| Performance Outcome: | Pump is engaged, all pressure control and vehicle safety devices are set, the rated flow of the nozzle is achieved and maintained, and the apparatus is monitored for potential problems. |
| Conditions: | Given the sources specified in the following list: (1) Internal tank (2) Pressurized source (including connection to a hydrant or supply line from another pumping source) (3) Static source (4) Transfer from internal tank to external source |
| Candidate Directive: | “Produce effective hand or master streams.” |

| NO. | TASK STEPS | TEST | |
|-----|--|------------|--------------|
| | | Successful | Unsuccessful |
| 1 | Pump engaged. | | |
| 2 | Pressure control devices set. | | |
| 3 | Vehicle safety devices set. | | |
| 4 | Rated flow of the nozzle achieved and maintained. | | |
| 5 | Assembled hose lines, nozzles, valves, and appliances. | | |

Evaluator/Candidate Comments:



Candidate: _____

Successful

Evaluator: _____

Unsuccessful

Date: _____

1002-PROCESS 19

| | |
|-----------------------------|--|
| Standard: | NFPA 1002 – 2017 edition – 5.2.5 |
| Task: | Pump a supply line of 2½ in. (65 mm) or larger to the next pumper in the relay. |
| Performance Outcome: | The correct pressure and flow are provided to the next pumper in the relay. |
| Conditions: | Given a relay pumping evolution, the length and size of the line and the desired flow and intake pressure. |
| Candidate Directive: | “Pump a supply line of 2½ in. (65 mm) or larger to the next pumper in the relay.” |

| NO. | TASK STEPS | TEST | |
|-----|---|------------|--------------|
| | | Successful | Unsuccessful |
| 1 | Correct pressure and flow provided to the next pumper in the relay. | | |

Evaluator/Candidate Comments:



Candidate: _____

Successful

Evaluator: _____

Unsuccessful

Date: _____

1002-SKILL-20

| | |
|-----------------------------|----------------------------------|
| Standard: | NFPA 1002 – 2017 edition – 5.2.6 |
| Task: | Produce a foam fire stream. |
| Performance Outcome: | Proportioned foam is provided. |
| Conditions: | Given foam-producing equipment. |
| Candidate Directive: | “Produce a foam fire stream.” |

| NO. | TASK STEPS | TEST | |
|-----|-----------------------------|------------|--------------|
| | | Successful | Unsuccessful |
| 1 | Proportioned foam provided. | | |

Evaluator/Candidate Comments:



Candidate: _____

Successful

Evaluator: _____

Unsuccessful

Date: _____

1002-PROCESS 21

| | |
|-----------------------------|---|
| Standard: | NFPA 1002 – 2017 edition – 5.2.7 |
| Task: | Supply water to fire sprinkler and standpipe systems. |
| Performance Outcome: | Water is supplied to the system at the correct volume and pressure. |
| Conditions: | Given specific system information and a fire department pumper. |
| Candidate Directive: | “Supply water to fire sprinkler and standpipe systems.” |

| NO. | TASK STEPS | TEST | |
|-----|-------------------------------|------------|--------------|
| | | Successful | Unsuccessful |
| 1 | Water supplied to the system. | | |
| 2 | Pressure is correct. | | |
| 3 | Volume is correct. | | |

Evaluator/Candidate Comments:
