



Refuse Containers

October 2011

Fire Protection and Life Safety Regulation Bylaw 2011 No. 7108

20. Containers for Collection of Combustible Refuse

- (1) All containers used for the collection of Combustible Refuse in quantities exceeding five cubic feet shall be constructed of solid sheet non-combustible material.
- (2) Each container referred to in section 20(1) shall have easy closing lids that must be operational at all times. Lids may be constructed of heavy plastic.
- (3) Containers referred to in section 20(1) shall be located at least ten feet from any building or fuel supply tank unless otherwise approved by the Fire Chief.
- (4) Containers that are intended for temporary collection of combustible construction material are exempt from section 20(2) and 20(3) of this Bylaw.

Bylaw Fines

20(1)	Failure to store combustible materials in proper container	\$200.00
20(2)	Container without lid	\$200.00
20(3)	Store within 10 feet of building or fuel tank	\$200.00