



- NOTE(S)**
1. SEE MANUAL FOR INSTALLATION AND ADJUSTMENTS.
  2. MATERIAL SPECIFICATIONS AND COATING PROVIDED UPON REQUEST.
  3. PLEASE VERIFY ELEVATION, CONTRACTOR AND/OR CUSTOMER, UPON APPROVAL, SHALL ASSUME FULL RESPONSIBILITY FOR CORRECTNESS OF FLAGGED DIMENSIONS.
  4. STANDARD CLEAN CAST IRON PARTS (REMOVAL OF LOOSE RUST, MILL SCALE, AND PAINT BY AIR HOSE, SCRAPING, & WIRE BRUSH)
  5. STANDARD SHOP COAT: 2 ML PRECISION TECHNICAL COATING CORPORATION SPRAY MACHINERY ENAMEL 355-0-45 (328 VOC) ORANGE ON COVER 355-B-19 (338VOC) BLACK ON SEATS & KEEPER

- NOTE(S)**
1. ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE NOTED.
  2. ALL ELEVATIONS IN METRES UNLESS OTHERWISE NOTED.

**REFERENCE(S)**  
 SLUICE VALVE GATE INSTALLATION DETAILS PROVIDED BY ARMTEC LIMITED PARTNERSHIP, DATED AUGUST 22, 2014.

ISSUED FOR REVIEW

CLIENT  
 CITY OF NANAIMO

PROJECT  
 COLLIERY DAMS - AUXILLARY SPILLWAY  
 NANAIMO, B.C.

CONSULTANT

VANCOUVER OFFICE  
 SUITE 200 - 2920 VIRTUAL WAY  
 VANCOUVER, BC, V5M 0C4  
 CANADA  
 [+1] (604) 296 4200  
 www.golder.com

TITLE  
**SLUICE GATE DETAILS**



REV.	YYYY-MM-DD	DESCRIPTION	DESIGNED	PREPARED	REVIEWED	APPROVED
A	2015-10-28	ISSUED FOR REVIEW	JG	SRR	RM	BD

PROJECT NO.	PHASE	REV.	of	FIGURE
13-1447-0516	4000	A		C-02

Path: \\golder\gis\gdp\Bumaby\CAD\_GIS\Client\City\_of\_Nanaimo\92\_PROJECTS\13-1447-0516\92\_PRODUCTION\4000\4500\_DRAWINGS\1 File Name: 1314470516-4000-4500-C-2.dwg

25 mm IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM ANSI D